



DEPARTMENT OF THE ARMY  
UNITED STATES ARMY GARRISON STUTTGART  
UNIT 30401  
APO AE 09107-0401

IMSG-ZA

19 December 2019

MEMORANDUM FOR Executive Deputy to the Commanding General, Installation Management Command, 2405 Gun Shed Road, Joint Based San Antonio Fort Sam Houston, TX 78234-1223

SUBJECT: USAG Stuttgart Calendar Year 2019 Comprehensive Fire and Safety Inspection of Child and Youth Programs

1. The Comprehensive Fire and Safety Inspection was conducted at USAG Stuttgart from 7 - 24 October 2019. The Comprehensive Fire and Safety Final Corrective Action Report (CAR) is located in the Child and Youth Enterprise Reporting Tool (CYERT).
2. The Comprehensive Fire and Safety Inspection resulted in 18 deficiencies. All deficiencies have been corrected with the following exceptions:
  - a. Criteria #: B.2.a.8 and B.3.m.7, Facility/Bldg #: Kelley CDC II/3368  
Description: Inoperable Facility Sprinkler System.  
Date of Equivalency Approved: 1 October 2019, IMCOM-190430-9TYL  
Status of Finding Correction: DPW has assigned WO#N1-00307-9P and contractors are currently performing repairs to defective system.  
Suspense date NTE 26 January 2020.
3. If further information is required, please contact Ms. Jamie M. Ruffini, Child and Youth Services Coordinator, at DSN 314-596-5327, Commercial 09641-70596-5327 or by email at jamie.m.ruffini2.naf@mail.mil.

JASON W. CONDREY  
COL, IN  
Commanding

Close Out Memo